

# System Water Test

## 62254

- Maintain maximum system efficiency
- Helps prevent boiler breakdown
- Extends the lifespan of the boiler
- Easy to use on-site test - enables corrective action to be taken immediately



A simple and easy-to-use turbidity test to check the quality of system water and determine appropriate treatment to ensure the system works at optimum efficiency, and the boiler is fully protected.

### Application

Fill the tube with a 50 ml sample of system water taken from either the boiler or a radiator. Look down the tube and focus on the black and yellow target at the base of the tube. Depending on the cleanliness of water, there are 4 recommended treatment options;

1. The target is clearly visible and the system is adequately inhibited (with the boiler displaying a retreatment label) - No action required
2. The target is clearly visible but the system may not be adequately inhibitor (no retreatment label is displayed on the boiler) - Dose with Fernox Protector F1
3. The target is visible but blurred indicating contaminants are present in the system water - Fit a Fernox TF1 Filter and dose with Fernox Protector+ Filter Fluid
4. The target is not visible indicating a heavily sludged and dirty system due to corrosion and limescale formation - Clean the system with Fernox F3 Cleaner or Fernox Power Cleaner F8, fit a Fernox Filter and dose with Fernox Protector+ Filter Fluid

### Single Item

Height mm	52
Width mm	200
Depth mm	59
Weight kg	0.300
Barcode EAN	5014551622548

### Outer Carton

OCU Barcode	5.01455E+12
-------------	-------------

Last modification

18-02-2021 (d/m/y)